



NXRT Online UPS

1000VA, 1500VA, 2000VA, 3000VA Models

User & Installation Manual

Table of Contents

EMC Statements - FCC Part 15.....	5
ICES-003.....	5
Declaration of Conformity Request.....	5
Special Symbols.....	7
Introduction.....	8
Product Description.....	8
Double Conversion Online Technology.....	8
Diagnostic Tests.....	9
System Configuration.....	10
LED Description.....	12
LCD Descriptions.....	12
RS-232 Standard Interface.....	13
SNMP Communications Option.....	13
Remote Emergency Power Off (REPO) Port.....	13
Determining The Power Requirements Of Your Equipment.....	14
Hardware Installation Guide.....	14
Safety Information.....	14
Storage and Transportation.....	14
Environment.....	15
Installation.....	15
Rack-Mount Installation Steps.....	20
UPS Rail Installation Instructions to 19" Cabinet.....	20
User's Operations.....	25
Turning Off the UPS when connected to an AC source.....	25
Starting the UPS from a DC source (cold start).....	25
Turning Off the UPS when in DC Mode.....	25
Self Test Operation.....	25
Audible Alarm silence in DC Mode or Fault Mode.....	26

Batteries.....27

 Replacing The Battery.....27

Troubleshooting.....29

LCD Fault Codes.....30

Specifications.....31

Shipping List..... 32

Obtaining Service.....33

Xtreme Power Conversion Limited Warranty.....34

Xtreme Power Conversion Load Protection Policy.....35

Appendix A: Extended Battery Pack User Guide.....38

 Estimated Run Time for UPS with Extended Battery Packs.....38

 Extended Battery Pack Configuration.....39

 LED Description.....40

 Extended Battery Pack Operation.....40

 Extended Battery Pack Installation.....41

Appendix B: Charger Battery Pack User Guide.....42

 Estimated Run Time for UPS with Charger Battery Packs.....42

 Charger Battery Pack Configuration.....43

 LEDDescription.....44

 Charger Battery Pack Operation.....44

 Charger Battery Pack Installation.....46

 Charger Battery Pack Q & A.....46

Thank you for selecting this Uninterruptible Power Supply (UPS). It provides you with protection for connected equipment. **Please read this manual before installing** the NXRT-Series UPS models NXRT-1000, NXRT-1500, NXRT-2000 and NXRT-3000 as it provides important information that should be followed during installation and maintenance of the UPS and batteries, allowing you to correctly set up your system for the maximum safety and performance. Included is information on customer support and service, if it is required. If you experience a problem with the UPS, please refer to the Troubleshooting section in this manual to correct the problem. If the problem is not corrected, please collect information so that the Technical Support personnel can more effectively assist you.

EMC Statements - FCC Part 15

Notice: Pursuant to section 15 of the FCC rules, this product has been tested and thereby complies to the conditions of a Class B (NXRT-1000, NXRT-1500) and Class A (NXRT-2000, NXRT-3000) digital device, which have been established for offering sufficient protection against dangerous interference for installation in a residential area. Installation and use of the equipment should comply with the instructions provided in order to avoid such interference due to the amount of radio frequency energy that is radiated and generated by the equipment. In spite of this, we cannot assure that a certain amount of interference may not occur in some installations. If, by turning on and off, it can be deduced that your radio or television reception is found to be influenced by harmful interference from the equipment, it is recommended to use one of the following preventive measures.

- Place the receiving antenna in a separate location or orientation.
- Ensure a greater distance is achieved between the receiver and the equipment.
- Ensure that your equipment is connected to an outlet on a separate circuit than the receiver.
- Contact a technician experienced with radio and TV or a dealer for further assistance.

ICES-003

This Class B Interference Causing Equipment meets all requirements of the Canadian Interference Causing Equipment Regulations ICES-003. Cet appareil numérique de la classe B respecte toutes les exigences du Règlement sur le matériel brouilleur du Canada.

Declaration of Conformity Request

Units labeled with a UL mark comply with the following standards and directives:

- UL 1778

CAUTION: A shielded-type power cord is required in order to meet FCC emission limits and to prevent interference to the nearby radio or TV reception. It is essential that only the supplied power cord be used. Use only shielded cables to connect I/O devices to this equipment.

WARNING: Any changes or modifications not expressly approved by the manufacturer of this device could void the user's authority to operate the equipment.

IMPORTANT SAFETY INSTRUCTIONS: (SAVE THESE INSTRUCTIONS)

CAUTION! (UPS having Internal Batteries): Risk of electrical shock – Hazardous live parts inside this unit are energized from the battery supply even when the input AC power is disconnected.

CAUTION! (No User serviceable Parts): Risk of electrical shock, do not remove cover. No user serviceable parts inside. Refer servicing to qualified service personnel.

CAUTION! (Non-isolated Battery supply): Risk of electric shock, battery circuit is not isolated from AC input, hazardous voltage may exist between battery terminals and ground. Test before touching.

WARNING! (Fuses): To reduce the risk of fire, replace only with the same type and size of fuse.

WARNING! Unit intended for installation in a controlled environment.

CAUTION! Do not dispose of batteries in a fire, the battery may explode.

CAUTION! Do not open or mutilate the battery, released electrolyte is harmful to the skin and eyes.

CAUTION! A battery can present a risk of electric shock and high short circuit current. The following precaution should be observed when working on batteries:

- Remove watches, rings or other metal objects.
- Use tools with insulated handles.

To reduce the risk of electric shock, disconnect the UPS from the main supply before installing a computer interface signal cable. Reconnect the power cord only after signaling interconnections have been made.

Servicing of batteries should be performed or supervised by personnel with knowledge of batteries and the required precautions. Keep unauthorized personnel away from batteries.

These UPS units are extremely heavy. Do not install the UPS in a rack or enclosure by its front two ears only. Adjustable rack rails are required for this type of installation.

The instructions contained within this safety manual are deemed important and should be closely followed at all times during installation and follow-up maintenance of the UPS and batteries.

**CAUTION**

The unit has a dangerous amount of voltage. If the UPS indicator is on, the unit's outlets may have a dangerous amount of voltage even when not plugged into the wall outlet because the battery may continue to supply power.

Care should be taken to undertake installation indoors, free from electrically-conductive particles which are under temperature and humidity control, in order to reduce the risk of electric shock.

It is best to disconnect the device using the power supply cord. Ensure that the equipment is placed in a position near the outlet where easily accessible.

Except for replacing the batteries, all servicing on this equipment must be carried out by qualified service personnel.

Before conducting any maintenance, repair, or shipment, first ensure that everything is turned off completely and disconnected.

For additional safety instructions, please use the Safety Manual as a reference.

Special Symbols

The following symbols used on the UPS warn you of precautions:



RISK OF ELECTRIC SHOCK - Please observe the warning that a risk of electric shock is present



CAUTION: REFER TO OPERATOR'S MANUAL - Refer to the operator's manual for additional information, such as important operating and maintenance instructions.



SAFE GROUNDING TERMINAL - Indicates primary safe ground



LOAD ON/OFF – Pressing the button turns on/off the output receptacles and the indicator light.



RJ45 RECEPTACLE – The receptacle provides network interface connections and telephone or telecommunications equipment should not be plugged into it.



Please do not discard of the UPS or the UPS batteries as the UPS may have valve-regulated lead-acid batteries. Please recycle batteries appropriately.

Introduction

The information provided in this manual covers single phase 1000-3000 VA uninterruptible power systems, their basic functions, operating procedures, options available and emergency situations. It also includes information on how to ship, store, handle, and install the equipment. Only detailed requirements of the UPS units are described herein, and installation must be carried out in accordance with this manual. Electrical installation must also carefully follow local legislation and regulations. Only qualified personnel should conduct these installations as failure to acknowledge electrical hazards could prove to be fatal.

Product Description

Many different kinds of sensitive electrical equipment can be protected by an Uninterruptible Power Supply (UPS) including computers, workstations, process control systems, telecommunications systems, sales terminals, other critical instrumentation, etc. The purpose of the UPS is to protect these systems from poor quality utility power, complete loss of power, or other associated problems.

Electrical interference exists in many forms, causing problems in AC power, from lightning, power company accidents and radio transmission motors, air conditioners, and vending machines. Protection of sensitive electrical equipment is vital to protect against power outages, low or high voltage conditions, slow voltage fluctuations, frequency variations, differential and common-mode noise, transients, etc.


To prevent power line problems from reaching critical systems causing damage to software, hardware, and equipment malfunctions, the UPS maintains constant voltage, isolating critical load output and cleaning the utility AC power.

Double Conversion Online Technology

A double conversion on-line technology UPS provides completely isolated, clean, uninterrupted single-phase power to your critical systems, while maintaining the batteries for their maximum potential. In the event that the power failure lasts longer than the UPS backup time, the UPS will shut down avoiding battery damage. When the input AC voltage returns, the UPS will automatically return online to recharge the batteries.

As shown in block diagram:

- An input filter reduces transients on the incoming utility.
- To maintain full battery charge, the AC input power is rectified and regulated in the rectifier feeding power to the battery converter and inverter.
- DC power is converted to AC in the inverter, passing it on to the load.
- Power is maintained from the battery during a power failure.
- The converter increases voltage appropriately for the inverter.



Diagnostic Tests

When the UPS is started, a diagnostic test is automatically executed, checking the electronics and batteries, reporting any problems on the LCD display. A diagnostic test can also be performed manually from the front panel at any time.



System Configuration



The UPS device and the internal batteries make up the system. Depending on the site and load requirements of the installation, certain additional options are available for the solution.

Planning a UPS system, the following should be taken into consideration:

- The total demand of the protected system shall dictate the output power rating (VA). Allow a margin for future expansion or calculation inaccuracies from measured power requirements.
- Backup time required will indicate the battery size needed. If the load is less than the UPS nominal power rating, then actual backup time is longer.
- The following options are available:
 - o Extended Battery Packs
 - NXRT-EBP1 for 1000
 - NXRT-EBP2 for 1500
 - NXRT-EBP3 for 2000/3000
 - o Connectivity Options –SNMP/WEB card
 - o Xtreme Power Distribution Units (XPDU)

See the Specification section of this manual for additional model information.





LED Description

The UPS has three LED's on the front control panel. These LED's allow the user to quickly understand if any action is needed.

Red LED

If this LED is illuminated it indicates a fault and the UPS will have no output. Faults that would indicate this alarm condition include:

- Overload
- Inverter fault
- BUS fault
- Over temperature fault

Yellow LED

If this LED is illuminated it indicates the user needs to take some action, and included:

- UPS in Bypass Mode
- Batteries Overcharged
- Charger fault
- Fan fault
- Batteries discharged to low voltage level

Green LED

If this LED is illuminated it indicates that everything is normal and the UPS is being powered by incoming AC utility or by the batteries.

LCD Descriptions

There are four lines of information in the LCD display. Each line provides specific information related to the unit status and/or operation. Line information will be described from top to bottom with the top being line one.

Line One

Provides data in to numeric sections, with the data corresponding to the applicable category in line one and two.

Line Two

Allows the user to identify which variable information is being displayed.

- Input
- Output
- Battery
- Load
- Temperature

Line Three

This is a graphics section with load graphics on the left and battery graphics on the right. The failure icon will appear in this section when a failure occurs.


Line Four

This indicates the status of the UPS.

- ON LINE = utility mode
- ON BATT = battery mode
- ON BPS = bypass mode
- UPS OFF = standby mode

RS-232 Standard Interface

The RS-232 interface uses a 9-pin female D-sub connector. Information provided includes data about utility, load and the UPS. The interface port pins and their functions are identified in the following table:



PIN #	FUNCTIONS
1,4,6,7,8	NOT USED
2	TRANSMIT
3	RECEIPT
5	GND
9	REMOTE WAKE UP

CAUTION: MAX RATED VALUES 12VDC

SNMP Communications Option

The UPS provides an intelligent slot for internal or external network card. This special intelligent network card can be compatible with popular software and hardware found on the web and in operating systems. It can support operating systems such as HP Open View, IBM Netview, SUN Netmanager, etc. This enables the UPS to provide instant UPS and power information over the network. Please contact your reseller for additional details.

Notes

The UPS can be monitored through the RS232 interface or the SNMP card, but only one way at a time. The user can choose RS232 or SNMP communications through the communications switch on the rear panel of the UPS. RS232 is chosen if the switch is depressed to the RS232 position, and SNMP is chosen if the switch is depressed to the SNMP position. When there are two or more monitored pieces of equipment, the ground of each piece of equipment should be shared. The SNMP card is configured as DHCP by default IP setting.

Remote Emergency Power Off (REPO) Port

A customer supplied switch located remotely can be used to close the REPO connection and allows the UPS output receptacles to be switched off. Since the REPO shuts down the equipment immediately, orderly shutdown procedures are not followed by any power management software. The UPS will have to be manually restarted in order to regain power to the outlets on the UPS.

Determining The Power Requirements Of Your Equipment

1. Make sure the total Volt-Amp (VA) requirements of your connected equipment does not exceed the maximum VA rating for the UPS. The maximum VA ratings are shown in the Specifications section of this document.
2. Ensure that the equipment plugged into the battery-powered outlets does not exceed the UPS rated capacity. If UPS rated capacities are exceeded, an overload condition may occur and cause the UPS to shut down and trip the circuit breaker.
3. If the power requirements of your equipment are listed in values other than Volt-Amps (VA), convert Watts (W) or Amps (A) into VA by doing the calculations below. Note: The equation below only calculates the maximum amount of VA that the equipment can use, not what is typically used by the equipment at any given time. Users should expect usage requirements to be approximately 60% of the value to estimate power requirements:

$$\text{Watts (W)} \times 1.43 = \text{VA or Amps (A)} \times 120 = \text{VA}$$

Add the totals for all of the equipment and multiply this total by 0.65 to calculate actual power requirements.

Note: Many factors can affect the amount of power that your computer system will require. The total load that you will be placing on the battery-powered outlets should not exceed 85% of the UPS capacity.

Hardware Installation Guide

Inspect the UPS upon receipt. The packaging is recyclable; keep it for reuse or dispose of properly.

Safety Information

Information presented here is vital to all personnel. Please read all Safety information.

Storage and Transportation

Please handle the UPS and associated equipment with extreme caution since a high amount of energy is contained in the batteries. Always keep the unit in an upright position as marked on the packaging, and never drop the unit.

Please adhere to the following instructions if the UPS is not installed immediately:

- Store the equipment as is in its original packing and shipping carton.
- Do not store in temperatures outside the range of -15°C to +25°C
- Ensure that the equipment is fully protected from wet or damp areas and from moist air.

In order to maintain the batteries, the UPS should be recharged every 6 months for at least 8 hours.

If flammable substances such as gases or fumes are present, or if the room is airtight, a hazardous situation may exist in which no electrical equipment should be operated.

The instructions in this manual explain how to install the UPS safely. Not acknowledging such electrical hazards may be fatal – keep this manual for future reference.

**WARNING!**

It is strongly recommended that the UPS cabinet not be opened as components have very high voltage and touching those components may be fatal. Only a qualified technician or authorized agent may service the unit.

The UPS unit's output receptacles carry live voltage even when not connected to an input voltage source. The UPS has its own internal energy source.

Environment


Ensure that all environmental concerns and requirements are met according to specifications listed in this document, otherwise the safety of installation personnel cannot be guaranteed, and the unit may malfunction.

Ensure that you remember the following when locating the UPS system and battery options:


- Avoid extremes of temperature and humidity. Maximum battery life can be attained with a recommended temperature range of +15°C to +25°C.
- Provide protection for the equipment from moisture.
- Space and ventilation requirements must be met. Ensure there is 100mm behind and 50mm on the sides of the UPS for proper ventilation.
- Ensure that the front of the UPS remains clear for user operation.

Installation

Standard brackets




**2U 5 IN 1 BRACKET FOR
NXRT-1000, NXRT-1500,
EBP1 & EBP2**




**3U 5 IN 1 BRACKET FOR
NXRT-2000, NXRT-3000
& EBP3**

19" Cabinet Ear Installation



NXRT-1000, NXRT-1500, NXRT-EBP1, NXRT-EBP2


Use M4 x 6 screws on places marked with letter A



NXRT-2000, NXRT-3000, NXRT-EBP3


Use M4 x 6 screws on places marked with letter A

Vertical Installation Steps




NXRT-1000, NXRT-1500, NXRT-EBP1, NXRT-EBP2


Use M4 x 6 screws on places marked with letter A




NXRT-2000, NXRT-3000, NXRT-EBP3

Use M4 x 6 screws on places marked with letter A

Wall-mounted Installation Steps

19" Rack mount using 5 in 1 bracket**NXRT-1000, NXRT-1500, NXRT-EBP1, NXRT-EBP2**

Use M5 x 12 screws on places marked with letter B

**NXRT-2000, NXRT-3000, NXRT-EBP3**

Use M5 x 12 screws on places marked with letter B


Rack-Mount Installation Steps

UPS Rail Installation Instructions to 19" Cabinet

Step 1



Step 2



Step 3



Step 4



Step 5



Step 6



Step 7



**ATTACH UPS OR EBP EAR ONTO CABINET U-BAR WITH
SCREWS ON BOTH LEFT & RIGHT SIDES**

Note: Any external Battery Packs must be installed next to or under the UPS. Please refer to Appendix A: Battery Pack User Guide for more information when installing these.

INITIAL CONNECTION AND STARTUP

Ensure that the UPS and optional battery packs are mounted correctly, and the UPS is disconnected from input power before proceeding.

1. Connect external battery packs (option)

CAUTION: CONNECT ONLY BATTERY PACKS PROVIDING THE SAME DC VOLTAGE AS THE UPS – PLEASE DOUBLE CHECK LABELING ON THE UPS AND BATTERY PACKS TO ASSURE PROPER VOLTAGES ARE CONNECTED. CONNECTING THE INCORRECT BATTERY PACK TO THE UPS MAY RESULT IN DAMAGE TO THE UPS AND/OR BATTERY PACK THAT WILL VOID THE WARRANTY.

- Ensure that the UPS is disconnected from AC input and is off while connecting the External Battery Packs. Ensure all battery breakers are in the “OFF” position.
- Remove the EBP covers on the UPS and EBP. Connect the battery cable that comes with the External Battery Pack between the External Battery Pack to the UPS.
- Secure the DC battery cable to the rear of the UPS, and the rear of the EBP by using M3 x 8 screws provided (2 each per connector end).
- Connect the 5-15P from the EBP to an input AC utility source per specifications.
- Connect a second battery pack to the first EBP in the same fashion if more than one is to be installed.
- Refer to Appendix A: Battery Pack User Manual for more details


2. Connect SNMP card (option)

- Remove the two screws securing the SNMP cover plate on the rear of the UPS, and slide the SNMP NetAgentII card into the slot. Secure the card into the slot with the two screws previously removed

3. Close the battery breakers on the Optional battery packs if installed.

4. Connect the AC input cable to the UPS and connect the other end to an approved grounded outlet. Once the UPS has been connected to an AC power source the internal charger will start charging the UPS batteries, at this point the yellow LED is illuminated, and the LCD displays “UPS OFF”. In this state the output voltage is zero, which means UPS has no output. Please realize that although you may start using the UPS immediately, maximum back-up time will still not be available, so it is recommended to charge the batteries for a minimum of 6 hours before use.

5. Start and configure the UPS



- Press and hold the ON/OFF button for more than 3 seconds to turn on the UPS. The UPS should now start its inspection of the internal functions, main synchronization, and inverter startup. Then power should start to be supplied via the outlets. Once turned on, the UPS will perform a self-test function, when the yellow LED turns to green, LCD displays “on line”, and means UPS is working in utility mode.

6. Configure the local monitoring software if desired.

- Insert the UPSilon 2000 CD (included with UPS packaging) into the CD ROM of the local computer.
- Select “Install program” from the Autorun menu and choose for the correct operating system.
- Follow the setup instructions. Enter the product key when prompted. The software key is found on the CD cover. Click finish when prompted.
- The UPSILON icon will appear in the system tray of the desktop near the system clock. Double click this icon to enlarge the program window.
- Connect the RS232 cable (included in the UPS packaging) to the Computer and UPS. Communication should start momentarily. If it does not, click on Settings up on the UPSilon toolbar, then select a different Comport until communication is established.
- Click on “Manual” in the UPSILON toolbar for further software configuration.
- **NOTE:** PLEASE VERIFY AUTOMATIC SHUTDOWN TIME PARAMETERS IN THE SETTINGS SECTION FOR

YOUR SPECIFIC INSTALLATION.

7. Configure the optional NetAgentII SNMP card if installed.
 - Insert the NetAgent Utility CD (included with SNMP packaging) into a PC and download the user manual
 - Install Netility from the AutoRun menu
 - Connect a network cable from the PC to the SNMP card.
 - Run Netility program and it will auto-search and list available NetAgents (SNMP card)
 - Highlight and click "Configure" to change the network settings on the NetAgent discovered.
 - Disconnect the cable to the PC and connect the SNMP card to your network.
 - Access the SNMP card via the network and make configuration changes using the manual downloaded previously.
 - **NOTE:** PLEASE VERIFY AUTOMATIC SHUTDOWN TIME PARAMETERS IN THE SETTINGS SECTION FOR YOUR SPECIFIC INSTALLATION.
8. After charging is complete, connect the loads to the UPS while monitoring the load levels via the UPS LCD or via the software.
 - Do not connect any devices that have the possibility of overloading the UPS.


Refer to the Troubleshooting section and/or Technical Support with any problems during setup.

User's Operations

The only operations that users are permitted to do are:

- Turning the UPS unit ON or OFF
- Operating the user interfaces
- Connecting data interface cables
- Changing the batteries

All such operations are to be performed exactly as instructed in this manual. The greatest care possible must be taken for any of these operations, and any change thereof may prove very hazardous to the operator.



Turning Off the UPS when connected to an AC source

- Press and hold the ON/OFF button for more than 3 seconds to turn off the UPS. This means the internal inverter has been deactivated.
- The unit will run a self test prior to the deactivation of the inverter.
- The green LED will be off and the yellow LED will be on. The LCD display will indicate "UPS OFF", which means the UPS is providing no output.

Starting the UPS from a DC source (cold start)

- Assure that the UPS has fully charged batteries and the internal battery pack is connected.
- Assure that there is no AC input power source and/or the unit is not plugged into an outlet.
- Press and hold the ON/OFF button for three seconds.
- Once turned on, the UPS will perform a self-test function, when the yellow LED turns to green, LCD displays "On Batt" – the UPS is now functioning in DC mode.

Turning Off the UPS when in DC Mode

- Press and hold the ON/OFF button for more than 3 seconds to turn off the UPS. This means the internal inverter has been deactivated.
- During the shutdown period, the UPS will run a self test. Once the self-test has been completed, assuming there is still no AC input, the LCD will no longer display information. This indicates the UPS has no output.

Self Test Operation

Please refer to the three operating buttons on the front panel of the UPS.

- Confirm the UPS is in "Utility Mode".
- Press and hold the "Function" button for a minimum of two seconds.
- The self-test will last for 10 seconds, during this time the LED's will be lit in a sequential, repeating fashion.

Audible Alarm silence in DC Mode or Fault Mode

- When the UPS is in DC Mode, the audible alarm will sound every four (4) seconds. Press and hold the “Function” Button for a minimum of two (2) seconds to disable the audible alarm.
- When the UPS is in Fault Mode, the audible alarm will continuously sound. Press and hold the “Function” Button for a minimum of two (2) seconds to disable the audible alarm.

Batteries

The life of batteries used in these UPS products is estimated at 3-6 years depending on level of usage. Once the battery is no longer useful and must be replaced, please contact service personnel for assistance.

Replacing The Battery

(QUALIFIED SERVICE PERSONNEL ONLY)

CAUTION! Read and follow the IMPORTANT SAFETY INSTRUCTIONS before servicing the battery. Service the battery under the supervision of Qualified Service Personnel knowledgeable of batteries and their precautions.

CAUTION! Use only the specified type of battery. See your dealer for replacement batteries.

CAUTION! The battery may present risk of electrical shock. Do not dispose of batteries in a fire as it may explode. Follow all local ordinances regarding proper disposal of batteries.

CAUTION! Do not open or mutilate the batteries. Released electrolyte is harmful to skin and eyes and may be toxic.

CAUTION! Although the battery system voltage is only 12VDC and 24VDC, the battery can present a high risk of short circuit current and electrical shock. The short circuit current capability of the battery is sufficient to burn wire or tools very rapidly, producing molten metal. Observe these precautions when replacing the battery:

1. Remove all watches, rings or other metal objects.
2. Only use tools with insulated handles.
3. Do not lay tools or metal parts on top of battery or any terminals.
4. Wear protective eye wear (goggles), rubber gloves, and boots.
5. Disconnect the charging source before connecting or disconnecting the battery terminals.
6. Determine if the battery is inadvertently grounded. If inadvertently grounded, remove the source of the ground. Contact with a grounded battery can result in electrical shock! The likelihood of such shock will be reduced if such grounds are removed during installation and maintenance (applicable to a UPS and a remote battery supply not having a grounded circuit).




Slide the plastic cover to the right.




Remove the M5x10 screws on the right side.





Remove plastic front cover



Locate the battery tray on the right front side of the UPS



Remove (4) M4x6 screws marked with letter A.



Remove the battery tray from the UPS.

Troubleshooting

Issue	Audible Alarm	Alarm Description	What You Should Do
The "Input" letters in the second row of the LCD are flashing	Two Beeps per second at startup for 8 total seconds	The Input Voltage or frequency may be beyond the normal acceptable range.	Verify that utility voltage and frequency is within acceptable range. If so, contact support.
The "Input" letters in the second row of the LCD are flashing	One beep per 2 minutes	Possible mis-wiring AC line and neutral line	Check wiring of input to UPS (reversed wiring, etc) Rewire, if necessary
Battery Indicator Flashing	One beep per second	Batteries are under-charged, disconnected or need to be replaced.	Check UPS batteries. If necessary reconnect batteries, wait 12 hours to charge or replace defective batteries
Utility Normal- UPS has no AC input	N/A	Possibility that circuit breaker on UPS has tripped	Reset circuit breaker
Insufficient battery run-time	Once every 4 seconds in DC mode	"On batt" displayed on LCD	<ul style="list-style-type: none"> If batteries are undercharged let UPS charge batteries at least 12 hours After charging, if runtime is still insufficient, replace with new batteries Reduce output load to lengthen runtime
UPS will not start after pressing the "On/Off" button	N/A	<ul style="list-style-type: none"> Insufficient time for button depression UPS has no battery connected Battery voltage is too low to power the load Fault has occurred inside the UPS 	<ul style="list-style-type: none"> Depress the "On/Off" button for at least three seconds Make sure the batteries are connected and the connector on the battery cartridge is "mated" correctly Plug the UPS in, remove all loads, and allow to charge for 12 hours Contact dealer for service details
Major fault detection by the UPS	Constant beep	Type of fault and fault code displayed on LCD.	Review abnormal process information table listed below in this manual and take appropriate action, If problem does not resolve contact supplier for service and provide error code(s)

LCD Fault Codes

	BYP MODE	LINE MODE	BAT MODE	BAT TEST MODE
BUS FAULT	62	05–25	01–21	40–41
INV FAULT	61–63	04	24	42
OVERHEAT	33	06	08	43
OP SHORT	/	16	02	44
OVERLOAD	/	03	09	45
FAN FAULT	36	28	38	46
CHARGE FAULT	07	07	/	/
BAT OVER	11	11	11	11

Specifications

MODEL NUMBER		NXRT-1000		NXRT-1500	NXRT-2000	NXRT-3000	
INPUT	Capacity	1000VA (700W)		1500VA (1050W)	2000VA (1400W)		3000VA (2100W)
	Voltage range	55–138VAC*					
	Frequency	50/60Hz auto-sensing					
OUTPUT	Voltage	120VAC					
	Waveform	Pure sine wave, zero transfer time					
	Frequency	50/60Hz auto-sensing					
	Efficiency	≥ 90%					
	Auto restart/start on battery	Yes					
	Overload capacity	110–150% for 30 sec; ≥ 150% for 200 ms					
	Crest factor	3:1					
	BATTERY	Battery quantity/type	(3) 12V 9AH / 36V		(4) 12V 7.2AH / 48V	(8) 12V 7.2AH / 96V	
	Recharge	Typically < 4 hours to 90% capacity					
PHYSICAL	UPS dimensions (W x D x H)	17.3 x 17.7 x 3.4 in		17.3 x 25.6 x 3.4 in		17.3 x 21.7 x 5.2 in	
	UPS weight	39.7 lbs		57.3 lbs		79.4 lbs	
	Line cord	6 ft, C13 to 5–15P		6 ft, 5–15P		6 ft, 5–20P	
	Receptacles	(6) NEMA 5–15R				(1) NEMA L5–20R + (4) NEMA 5–15/20R	
OPTIONAL BATTERY PACKS	Model number	EBP1 / CBP1		EBP2 / CBP2		EBP3 / CBP3	
	Battery quantity/type	2 x (3) 12V 9AH/36V		2 x (4) 12V 7.2AH/48V		2 x (8) 12V 7.2AH/96V	
	Dimensions (W x D x H)	17.3 x 17.7 x 3.4 in		17.3 x 25.6 x 3.4 in		17.3 x 21.7 x 5.2 in	
	Weight	58.4 lbs		75.0 lbs		113.6 lbs	
	Charger	CBP models contain a 2A DC charger and include a 5-15P input cord					
ENVIRONMENT	Operating temperature	32–104°F (0–40°C)					
	Audible noise	< 40dBA					
	Altitude	11,500 ft above sea level					
INDICATORS & ALARMS	LCD display	Input/output voltage & frequency, online mode, backup mode, battery capacity, load level					
	Audible alarm	Beep every 4 sec (on battery)					
	UPS fault	Continuous beeping sound and LCD display					
APPROVALS		UL, cUL, FCC					
WARRANTY		3 years electronics, 3 years battery warranty (USA and Canada)					
COMMUNICATIONS INTERFACE		RS-232, EPO, intelligent slot for optional cards (Web/SNMP, Relay/dry contact)					
INCLUDED IN BOX		UPSILON CD, horizontal brackets, 5:1 brackets, user manual, 6ft DB9 cable					
AVAILABLE OPTIONS		5 year extended warranty, bypass distribution (XBDM), power distribution (XPDU)					

*Depending on load level

Shipping List

1. (1) UPS
2. (1) User's and Installation Manual
3. (1) 6 ft RS232 cable
4. (1) UPSILON CD (monitoring software)
5. (2) sets of 5-in-1 mounting brackets
6. (1) set of horizontal mounting brackets

Obtaining Service

If the UPS requires Service:

1. Use the TROUBLESHOOTING section in this manual to eliminate obvious causes.
2. Verify there are no circuit breakers tripped.
3. Call your dealer for assistance. If you cannot reach your dealer, or if they cannot resolve the problem, call Xtreme Power Conversion Corp Technical Support at 800.582.4524. Technical support inquiries can also be made at support@xpcc.com. Please have the following information available BEFORE calling the Technical Support Department:
 - Your name and address.
 - The serial number of the unit.
 - Where and when the unit was purchased.
 - All of the model information about your UPS.
 - Any information on the failure, including LED's that may or may not be illuminated.
 - A description of the protected equipment, including model numbers if possible.
 - A technician will ask you for the above information and, if possible, help solve your problem over the phone. In the event that the unit requires factory service, the technician will issue you a Return Material Authorization number (RMA).

If you are returning the UPS to Xtreme Power for service, please follow these procedures:

1. Pack the UPS in its original packaging. If the original packaging is no longer available, ask the Technical Support Technician about obtaining a replacement set of packaging material. It is important to pack the UPS properly in order to avoid damage in transit. Never use Styrofoam beads for a packing material.
2. Include a letter with your name, address, daytime phone number, RMA number, a copy of your original sales receipt, and a brief description of the problem.
3. Mark the RMA number on the outside of all packages. Xtreme Power cannot accept any package without the RMA number marked on the outside of the boxes.
4. Return the UPS by insured, prepaid carrier to the address provided by the Technician.
5. Refer to the Warranty statements in this manual for additional details on what is covered.

Xtreme Power Conversion Limited Warranty

Xtreme Power Conversion (XPC) Corporation warrants Xtreme Power Conversion equipment, when properly applied and operated within specified conditions, against faulty materials or workmanship for a period of **three years for NXRT-Series products** from the date of purchase. XPC Corporation warrants **internal batteries for a period of three years** from the date of purchase. For equipment sites within the United States and Canada, this warranty covers repair or replacement, at the sole discretion of XPC Corporation. The customer is responsible for the costs of shipping the defective product to XPC Corporation. XPC Corporation will pay for ground shipment of the repaired or replacement product. This warranty applies only to the original purchaser.

If equipment provided by XPC Corporation is found to be **Dead-on-Arrival (DOA)**, XPC Corporation will be responsible for the costs of shipping product to and returning equipment from the customer in a timely manner as agreed to with the customer, once the customer has requested and received a **Return Material Authorization (RMA)** number. DOA equipment is defined as equipment that does not properly function according to user documentation when initially received and connected in conjunction with proper procedures as shown in the user documentation or via support provided by XPC Corporation personnel or authorized agents.

This warranty shall be void if (a) the equipment is repaired or modified by anyone other than XPC Corporation or a XPC Corporation approved third party; (b) the equipment is damaged by the customer, is improperly used or stored, is subjected to an adverse operating environment, or is operated outside the limits of its electrical specifications; or (c) the equipment has been used or stored in a manner contrary to the equipment's operating manual, intended use or other written instructions. Any technical advice furnished by XPC Corporation or a XPC Corporation authorized representative before or after delivery with regard to the use or application of Xtreme Power Conversion equipment is furnished on the basis that it represents XPC Corporations best judgment under the situation and circumstances, but it is used at the recipient's sole risk.

EXCEPT AS STATED ABOVE, XPC Corporation DISCLAIMS ALL WARRANTIES, EXPRESSED OR IMPLIED, INCLUDING WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE.

EXCEPT AS STATED ABOVE, IN NO EVENT WILL XPC Corporation BE LIABLE FOR DIRECT, INDIRECT, SPECIAL, INCIDENTAL, OR CONSEQUENTIAL DAMAGES ARISING OUT OF THE USE OF Xtreme Power Conversion EQUIPMENT, including but not limited to, any costs, lost profits or revenue, loss of equipment, loss of use of equipment, loss of software, loss of data, cost of substitutes, or claims by third parties. Purchaser's sole and exclusive remedy for breach of any warranty, expressed or implied, concerning Xtreme Power Conversion equipment, and the only obligation of XPC Corporation under this warranty, shall be the repair or replacement of defective equipment, components, or parts; or, at XPC Corporations sole discretion, refund of the purchase price or substitution of an equivalent replacement product.

Xtreme Power Conversion Load Protection Policy

THIS POLICY IS NOT A WARRANTY. REFER TO **THE XPC CORPORATION, INC. LIMITED WARRANTY** FOR INFORMATION CONCERNING THE WARRANTY FOR YOUR XPC PRODUCT. THE LIMITATIONS AND CONDITIONS CONTAINED IN THIS POLICY DO NOT AFFECT **THE TERMS OF THE XPC LIMITED WARRANTY**.

Definitions:

1. "Product" means a Standard 120, 208, or 240 Volt power protection device that is used in the United States and Canada. This policy does not include custom manufactured products.
2. "Power Disturbance" means an AC power line transient (telephone line or Local Area Network, if applicable), spike or surge.
3. "Connected Equipment" properly connected electronic equipment
4. "Fair Market Value" of damaged Connected Equipment as determined by XPC shall be the lower of (a) the average price the same or similar items are being sold for on eBay, (b) the price list of Orion Blue Book (or if such price list is no longer published, a published or announced price list reasonably selected by XPC), (c) the lowest price the same or similar items can be purchased for in the United States or (d) the total amount of all payment(s) you have or are entitled to receive from insurance, other warranties, extended warranties, a legal liability claim or from other sources or persons for the damaged Connected Equipment.
5. "Purchaser" means the person or entity that originally purchased the Product from an authorized reseller or distributor of XPC Products.

The Purchaser of this Product is protected, for the term of the XPC Limited Warranty, against certain losses caused by a Power Disturbance for properly connected electronic equipment (referred to as the "Connected Equipment") subject to certain terms and conditions provided below.

This policy applies only to the original purchaser of the Product. If the Product is transferred or sold to another person or entity, this policy is void.

Load Protection Policy Dollar and Period Limits

For purchasers that meet the qualifications and conditions set forth in this policy, XPC will provide reimbursement (cost of repair or fair market value as determined by XPC) during the period limits and up to the dollar limits stated as follows:

PRODUCT	DOLLAR LIMIT	PERIOD OF COVERAGE
XVT	25,000	Term of XPC Limited Warranty
XST	25,000	Term of XPC Limited Warranty
S70	25,000	Term of XPC Limited Warranty
XPRT 6kVA & 10kVA	50,000	Term of XPC Limited Warranty
NXRT	50,000	Term of XPC Limited Warranty
P90, P90L, P90g, P90Lg	50,000	Term of XPC Limited Warranty
T90	50,000	Term of XPC Limited Warranty
TX90, TX90i	50,000	Term of XPC Limited Warranty

This Load Protection Policy is not deemed "first dollar" coverage. XPC's obligation is reduced by any amounts that the Purchaser is entitled to recover, from other sources regarding the Connected Equipment, including, but not limited to, insurance, other warranty, extended warranty, or legal liability, regardless of whether or not the Purchaser makes a claim for recovery.

Eligibility for Coverage Under the Load Protection Policy

1. The Product must be registered on the XPC website, www.xpcc.com, within 10 days of purchase. All required information must be provided, and Purchaser should retain a copy for Purchaser's records. When registering on the website, Purchaser must list all connected equipment that is directly connected to the

product. Only those devices registered in that manner will be covered.

2. All Connected Equipment must be UL or CSA approved.
3. The Product must be plugged into a properly wired and grounded outlet. Use of input surge devices, extension cords, adapters, ground wires, or electrical connections not manufactured by XPC voids the XPC Load Protection Policy. No other surge protection device may be connected to the output sockets of the Product. The installation must comply with all applicable electrical and safety codes set forth pursuant to the NEC.
4. The Product must have undeniable physical evidence of a Power Disturbance that directly and proximately caused the damage;
5. The Connected Equipment must have been damaged by a Power Disturbance on a properly installed, grounded, and National Electric Code, ("NEC"), code-compliant 120, 208, 240 Volt AC power line in the United States or Canada, by a Power Disturbance on standard telephone land line or PBX telephone equipment line that is properly installed and connected to an RJ11 port on the Product; or by a Power Disturbance on a standard Local Area Network connection that is properly installed and connected to an RJ45 port on the Product and (d) is directly plugged into, and properly connected to, the Product in its original condition which was properly operated when a Power Disturbance passed through the Product and (i) exhausts the protection capacity of the Product or (ii) damages the Product.
6. The Load Protection Policy does not apply if the Product has been operated in a failure mode or not in compliance with XPC operating instructions in the Product user's manual, or if the Connected Equipment has not been operated in compliance with the instructions and manuals of its manufacturer/vendor.
7. This policy is null and void if, XPC determines, in its sole discretion, that the Product has been tampered with or altered in any way.

What is Not Covered Under the Load Protection Policy:

The following damage is not covered by this Policy:

1. Restoration of lost data and reinstallation of software.
2. Damage from a cause other than AC power-line transients, except for damage due to telephone line, Local Area Network, or CATV transients, which is covered only if the Product offers such protection.
3. DAMAGE CAUSED BY FAILURE TO PROVIDE A SUITABLE INSTALLATION ENVIRONMENT FOR THE PRODUCT (INCLUDING, BUT NOT LIMITED TO, LACK OF A PROPER SAFETY GROUND).
4. Damage caused by the use of the Product for purposes other than those for which it was designed.
5. Damage caused by accidents, or natural disasters, including but not limited to, fire, flood, and wind.
6. Damage caused by abuse, misuse, alteration, modification, or negligence.
7. Any labor costs or travel, room and board expenses associated with the repair and/or restoration of lost or damaged hardware, software or data.

EXCEPT AS EXPRESSLY PROVIDED IN THIS POLICY, XPC SHALL NOT BE LIABLE FOR ANY DAMAGES WHATSOEVER, INCLUDING, BUT NOT LIMITED TO, DIRECT, INDIRECT, SPECIAL, INCIDENTAL, CONSEQUENTIAL, OR MULTIPLE DAMAGES ARISING OUT OF THE USE OF THE PRODUCT OR DAMAGE TO THE CONNECTED EQUIPMENT, REGARDLESS OF THE LEGAL THEORY ON WHICH SUCH CLAIM IS BASED, EVEN IF ADVISED OF THE POSSIBILITY OF SUCH DAMAGE. SUCH DAMAGES INCLUDE, BUT ARE NOT LIMITED TO, LOSS OF PROFITS, LOSS OF SAVINGS OR REVENUE, LOSS OF USE OF THE PRODUCT OR THE CONNECTED EQUIPMENT OR ANY ASSOCIATED EQUIPMENT, LOSS OF SOFTWARE, COST OF CAPITAL, COST OF ANY SUBSTITUTE EQUIPMENT, FACILITIES OR SERVICES, DOWNTIME, THE CLAIMS OF THIRD PARTIES, INCLUDING CUSTOMERS, AND INJURY TO PROPERTY.

Submitting a Load Protection Policy Claim:

1. Any claim under the Load Protection Policy must be made within 10 days of the date of alleged damage to the Connected Equipment.
2. Call the XPC technical support department at 1-800- 582-4524 and obtain a Load Protection Policy Returned Material Authorization (RMA) number. Have information on all applicable insurance or other resources of recovery/payment that is available to the Purchaser and the name of the power utility supplier for the location of the Connected Equipment. XPC will forward to the Purchaser a Load Protection Policy claims form, which

must be completed and filed with XPC within 30 days.

- Mark the Load Protection Policy RMA number on the Product the Purchaser is returning.
- Pack the Product in its original packaging or similar packing materials if the original packaging has been discarded. Enclose the completed Load Protection Policy claim form and a copy of the Purchaser's original sales receipt for the Product in the box.
- Mark the RMA number clearly on the outside of the box.
- Ship the Product (one-way shipping charges paid by the Purchaser) to:

XPC Corporation
230 Yuma Street
Denver, CO 80223
Attn: LPP RMA#

3. XPC will evaluate the Product to determine its level of functionality, and will examine the Product for evidence of damage from a Power Disturbance.
 - If XPCs' evaluation provides no evidence of damage from a Power Disturbance, XPC will send to the Purchaser (i) a report summarizing the tests performed and (ii) a rejection of claim notice.
 - If the Product shows evidence of damage from a Power Disturbance, XPC will request that all Connected Equipment for which a Load Protection Policy claim has been submitted, be sent for evaluation to either XPC or an authorized service center. If it is determined that the Connected Equipment has been damaged by a Power Disturbance, XPC will, in its sole discretion, issue payment to the Purchaser for either the cost of repair of the Connected Equipment or the Fair Market Value of the damaged Connected Equipment, up to the dollar limits stated above. XPC reserves the right to require the Purchaser to transfer title and deliver the Connected Equipment to XPC if it chooses to reimburse the Purchaser for the fair market value of the Connected Equipment. XPCs' maximum liability shall be reduced to reflect all such other payments or sources of recovery, whether applied for or not.
4. If XPC issues payment to the Purchaser to have the Connected Equipment repaired, the repair must be performed at a service center that is authorized by the manufacturer of the Connected Equipment. XPC reserves the right to contact the authorized service center directly to discuss repair costs and damage to the Connected Equipment to determine if it was caused by a Power Disturbance and the right to request that the service center forward the Connected Equipment or components of the Connected Equipment to XPC for inspection
5. Unless modified in writing signed by an officer of XPC and the Purchaser, the terms of this policy are the complete and exclusive agreement between the parties, superseding all prior agreements, oral or written, and all other communications between the parties relating to the subject matter of this agreement. No employee of XPC or any other party is authorized to make any representations beyond those made in this agreement concerning the Load Protection Policy.

XPC Corporation
230 Yuma Street
Denver, CO 80223
1.800.582.4524

Appendix A: Extended Battery Pack User Guide

Estimated Run Time for UPS with Extended Battery Packs

MODEL	LOAD		RUNTIME FOR QTY OF EXTENDED BATTERY PACKS IN MIN.		
	VA	WATTS	UPS	(1) EBP	(2) EBP
NXRT-1000	500	350	23	91	176
	1000	700	10	41	80
NXRT-1500	750	525	18	68	124
	1500	1050	9	32	60
NXRT-2000	1000	700	29	109	200
	2000	1400	14	52	97
NXRT-3000	1500	1050	18	67	123
	3000	2100	9	32	60

*For applications requirements of more than two EBP's, a CBP must be added. See Appendix B for additional information.

CAUTION: It is very critical to connect the correct voltage EBP with the UPS intended.

EBP1 is for NXRT-1000

EBP2 is for NXRT-1500

EBP3 is for NXRT-2000/3000


CONNECTING THE INCORRECT BATTERY PACK TO THE UPS MAY RESULT IN DAMAGE TO THE UPS AND/OR BATTERY PACK WILL VOID THE WARRANTY.

All EBP's have a different DC voltage configuration intended only for the UPS's listed above. PLEASE DO NOT MIX EBP's AND MAKE SURE YOU ONLY CONNECT THE EBP TO LIKE EBP's OR UPS INDICATED ABOVE. DC VOLTAGES ARE MARKED ON BOTH THE UPS AND THE EBP – MAKE SURE THEY MATCH.




Caution label on EBP cable connectors - PLEASE CHECK VOLTAGES CAREFULLY


Extended Battery Pack Configuration




EBP1 for NXRT-1000



EBP2 for NXRT-1500



EBP3 for NXRT-2000/3000



NXRT-EBP front panel

LED Description

The **Battery Test LED GREEN** indicates that the DC output of the Extended Battery Pack (EBP) is normal. To perform the Battery Test:

- Switch the breaker on the rear of the EBP to ON position
- Press the Battery Test Button on the front panel of the EBP
- The DC output from the EBP is normal when the Battery Test LED is illuminated

Prior to connecting EBP's, test each EBP to assure proper operation.

Extended Battery Pack Operation


The NXRT UPS System can be connected with up to two EBP's to increase the runtime when connected to the UPS supporting the load.

1. The DC Circuit Breaker on the rear of the EBP connects and disconnects the DC bus voltage from the EBP to the UPS. The DC Circuit Breaker will also trip to the OFF position in the event of an over-current condition in the EBP.



EBP2 rear view

2. The EBP's use a cable shipped with each EBP to "daisy chain" together additional EBP's to the first EBP being connected to the UPS in the appropriately labeled connector, or for connecting the first EBP to the UPS.



EBP's "daisy chain" to UPS or other EBP

Extended Battery Pack Installation

CAUTION: Extended Battery Pack (EBP) Installation should be performed by qualified service personnel.

1. Verify that the DC circuit breaker on the rear panel of the EBP is in the OFF position.
2. Turn the UPS OFF and disconnect the UPS Input Cord from the AC wall outlet.
3. Remove the EBP connector cover from the UPS rear panel.
4. Connect the external DC battery cable from the EBP to the appropriate connector on the UPS.
5. Secure the DC battery cable to both the rear of the UPS and the rear of the EBP by using M3 x 8 screws provided (2 each per connector end).
6. Repeat the above procedure for testing and securing each additional EBP required.
7. Move the DC circuit breaker on the rear of each EBP to the ON position. At this point the UPS will need to be started.

NOTE: If the EBP is going to be out of service or stored for six months or longer, the batteries must be re-charged for at least 36 hours every six months.

Appendix B: Charger Battery Pack User Guide

Estimated Run Time for UPS with Charger Battery Packs

MODEL	RUNTIME FOR QTY OF EXTENDED BATTERY PACKS IN MIN.								
	UPS	+ (1) EBP	+ (2) EBP	+ (2) EBP + (1) EBP	+ (3) EBP + (1) EBP	+ (4) EBP + (1) EBP	+ (4) EBP + (2) EBP	+ (5) EBP + (2) EBP	+ (6) EBP + (2) EBP
NXRT-1000	10	42	80	123	171	221	274	329	387
NXRT-1500	9	33	60	89	120	152	186	220	255
NXRT-2000	14	53	97	144	194	247	301	356	414
NXRT-3000	9	33	60	89	120	152	186	220	255

Note: one Charger Battery Pack (CBP) is recommended for every two Extended Battery Packs (EBP)

CAUTION: It is very critical to connect the correct voltage CBP with the UPS intended.

CBP1 is for NXRT-1000

CBP2 is for NXRT-1500

CBP3 is for NXRT-2000/3000


CONNECTING THE INCORRECT BATTERY PACK TO THE UPS MAY RESULT IN DAMAGE TO THE UPS AND/OR BATTERY PACK WILL VOID THE WARRANTY.

All CBP's have a different DC voltage configuration intended only for the UPS's listed above. PLEASE DO NOT MIX CBP's AND MAKE SURE YOU ONLY CONNECT THE CBP TO LIKE CBP's OR UPS INDICATED ABOVE. DC VOLTAGES ARE MARKED ON BOTH THE UPS AND THE CBP – MAKE SURE THEY MATCH.




Caution label on CBP cable connectors - PLEASE CHECK VOLTAGES CAREFULLY


Charger Battery Pack Configuration




CBP1 for NXRT-1000



CBP2 for NXRT-1500



CBP3 for NXRT-2000/3000



LED Description

The **Charging LED GREEN** indicates that the battery charger in the Charger Battery Pack is charging normally with the AC power cord attached to the Battery pack. AC power cord is only used for every third CBP installed.

The **Battery Test LED GREEN** indicates that the DC output of the Charger Battery Pack (CBP) is normal.

To perform the Battery Test:

- Switch the breaker on the rear of the CBP to ON position
- Press the Battery Test Button on the front panel of the CBP
- The DC output from the CBP is normal when the Battery Test LED is illuminated

Prior to connecting CBP's, test each CBP to assure proper operation.

Charger Battery Pack Operation


The NXRT UPS System can be connected to multiple Charger battery packs to increase the runtime when connected to the UPS supporting the load. Most UPS Systems are limited to one or two external battery packs because the UPS is responsible for the recharging and does not have the recharge capacity to handle the additional batteries to a full recharge. The NXRT UPS System overcomes this limitation by equipping each Charger battery pack (CBP) with its own charger, providing the user a way to achieve significantly more battery backup time.

1. The DC Circuit Breaker on the rear of the CBP connects and disconnects the DC bus voltage from the CBP to the UPS. The DC Circuit Breaker will also trip to the OFF position in the event of an over-current condition in the CBP.



CBP2 rear view

2. The CBP's use a cable shipped with each CBP to "daisy chain" together additional CBP's to the first CBP being connected to the UPS in the appropriately labeled connector, or for connecting the first CBP to the UPS.



CBP'S "daisy chain" to EBP

Note: do not connect the CBP charger power cord into the UPS receptacle.

3. The AC input cord is for connecting AC utility to operate the Charger contained in every CBP.
4. The input AC Circuit Breaker will trip to the OFF position in the event that the internal CBP charger draws excessive current.

Charger Battery Pack Installation

CAUTION: Charger Battery Pack (CBP) Installation should be performed by qualified service personnel.

1. Verify that the DC circuit breaker on the rear panel of the CBP is in the OFF position.
2. Turn the UPS OFF and disconnect the UPS Input Cord from the AC wall outlet.
3. Remove the CBP connector cover from the UPS rear panel.
4. Connect the external DC battery cable from the CBP to the appropriate connector on the UPS.
5. Secure the DC battery cable to both the rear of the UPS and the rear of the CBP by using M3 x 8 screws provided (2 each per connector end).
6. Repeat the above procedure for testing and securing each additional CBP required.

CAUTION: Do not use extension cords when connecting input AC power to UPS or CBP's

7. Move the DC circuit breaker on the rear of each CBP to the ON position. At this point the UPS will need to be started.
8. If the CBP's are plugged into an AC source and properly installed, the internal batteries will be charged when acceptable voltage is present. CBP's must be charged for a minimum of 6 hours for full battery time.

NOTE: If the CBP is going to be out of service or stored for six months or longer, the batteries must be recharged for at least 36 hours every six months.

Charger Battery Pack Q & A

1. Which CBP's do I connect to an AC input source?
 - It is recommended that every third CBP be connected to incoming AC utility to properly charge the batteries in a complete system. Leaving too many chargers connected may cause an over charge situation which could damage the batteries and void the warranty.
2. Which LED's are supposed to be lit on the front of each CBP?
 - When an CBP is connected to an AC input source and the unit is charging, a GREEN LED on the front of the CBP will be illuminated.
3. Are any LED's on the front of the CBP supposed to be lit if it is not connected to an AC input source?
 - No. The UPS and/or the CBP's that are plugged into an AC input source are responsible for charging the entire system. The CBP is still working and has the capability of providing DC voltage when needed. No LED on the front bezel will be illuminated.
4. The CBP is connected to an AC input source, why does the LED on the front of the CBP turn ON and OFF intermittently, and does this mean this CBP is not working?
 - The GREEN LED on the front of each CBP indicates that the charger contained in the CBP is charging. Under certain conditions when the batteries are 100% charged, the charger in the CBP will shut off and the LED will no longer be illuminated. This is normal operation for the CBP. The CBP is working properly.
5. Why don't the LED's on each CBP connected to an AC input source turn ON and OFF at the same time?
 - The charger on each CBP functions independently from the others. One CBP charger may be charging while another one might be at 100% and the charger turned off. This is normal operation of the CBP.